RFP-MCC-2313
Design / Build of Two Fire Stations
Addendum # 6

To All Bidders of RFP-MCC-2313:
Please note: the following addendum applies to RFP-MCC-2313 and shall be taken into consideration when preparing bid documents.

Questions and answers regarding the project below.

1. Is the Springhill Completion date set in stone? The consensus is that it is a fairly aggressive completion date, given that it will start in winter/spring.

   The Substantial Completion dates are provided in Section 18 of the RFP, Occupancy Date.

2. Given that the building requirements/needs are nearly exact, aside from the apparatus room in Springhill being larger, would it be acceptable if these designs were nearly the same? It keeps things streamlined during design and building.

   It is anticipated that some or all interest proponents will recommend designs that can be scaled for either site.

3. The community kitchen – after speaking with various consultants, they are concerned about the lack of specification on the range hood and that code modern code signifies that there should be fire suppression installed in the range hoods, even if no deep fryer is installed. It was indicated by consultants that fire suppression is expected even with minor cooking, as long as there is a chance of grease being produced it requires one. Special provisions to avoid fire suppression would need to be produced to ensure that there is no “food preparation” on site, only warming.

   Please refer to Addendum #5 related to fire suppression.

4. Just wondering if there is any specification on the existing Antenna.

   We do not have specifics on the existing Antenna in either location.

5. Just wondering if we need to match the current security system, CO monitoring system and video cameras, or if we can source as required.

   The successful proponent will source and provide new alarm systems, carbon monoxide detectors and security cameras. It is expected that newly source equipment, etc will be consistent in both locations.

6. Also, I missed taking photos of 2 pieces of equipment in Springhill, wondering if you could supply a contact so I can inquire? (secondary air compressor and LED message board)

   Photos of both are attached to this Addendum.


230 VOLTS ONLY
SCAN this with your mobile phone.
SCANNEZ ici avec votre téléphone portable.
SCANEA esto con tu celular.
CAMPBELL HAUSFELD
400
ST LOUVN
SAE 100R16 3500 PSI


NATIONAL DAY FOR TRUTH AND RECONCILIATION
FIRE DEPT. BUSINESS ONLY
Unauthorized Vehicles will be towed at Owners Expense
SFD

A signed copy of each Addendum must also be included with the bid submission. Failure to include this Addendum may be cause for rejection. If you have any questions, please contact Shelby Hum at shelbyhum@cumberlandcounty.ns.ca
ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum # 6