T-MCC-2414
Addendum #1

To All Bidders of T-MCC-2414:

Please note: the following addendum applies to T-MCC-2414 and shall be taken into consideration when preparing a bid.

Post caps are weather caps and can be any tight-fitting cap that suits that purpose. 2-1/2" PVC Sch 40 solvent weld cap should fit and could be held in place by screws and/or glued with good quality construction glue.

The design is based on the height of the sign at about 24" above ground. This will depend on the total height of sign being used as the height of the posts will be limited.

A signed copy of each Addendum must also be included with the bidder submission. Failure to include this Addendum may be cause for rejection. If you have any questions, please contact Shelby Hum at shelbyhum@cumberlandcounty.ns.ca

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #1