T-MCC-2505
Addendum #1

To All Bidders of T-MCC-2505:

Please note: the following addendum applies to T-MCC-2505 and shall be taken into consideration when preparing a bid.

Several questions have been raised regarding asphalt type and thickness, as well as general site conditions. See additional information below.

- **Site to be grubbed of all organics and top soil in preparation for the gravel as specified in the Tender. Contractor must achieve positive drainage.**
- **75mm asphalt overlay, type B-Mix asphalt**
- **We will work with successful bidder to provide basic topography and grades. Looking to achieve positive drainage.**
- **No permits required. The Municipality will oversee approval of work.**
- **Tenders should be submitted separately for breakout prices for gravel option only and then paving option separate.**

A signed copy of each Addendum must also be included with the bidder submission. Failure to include this Addendum may be cause for rejection. If you have any questions, please contact Shelby Hum at shelbyhum@cumberlandcounty.ns.ca

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #1