RFQ-MCC-2517
Addendum #2

To All Bidders of RFQ-MCC-2517:

The following questions have been raised regarding RFQ-MCC-2517:

Question 1:
Is the thickness of the proposed concrete surface 100mm? If not, can you confirm thickness?
Answer: Concrete path - Concrete 100 mm, 150 mm Type 1 Granular

Question 2:
What is the expected timeline for this work to be completed?
Answer: We understand weather plays a factor, however there is a preference for work completion prior to December 31, 2025, but can be flexible. Please provide ETA of work completion in your quote, should it differ from this schedule.

Question 3:
Is there a picture or a detail for the hydrant/hydrant base?
Answer: Please see photo. The expectation is for the hydrant base to be set in sonotube, or similar, secured with concrete.



Please note RFQ-MCC-2517, has been extended. **The new closing date is Nov. 27, 2025.**

A signed copy of each Addendum must also be included with the bidder submission. Failure to include this Addendum may be cause for rejection. If you have any questions, please contact Shelby Hum at shelbyhum@cumberlandcounty.ns.ca

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #2