

RFP-MCC-2620
Addendum #1

To All Bidders of RFP-MCC-2620

Please note: the following addendum applies to **RFP-MCC-2620 Destination Direction Tourism Signage** and shall be taken into consideration when preparing a bid.

The following questions have been raised:

Question 1:

The closing date is October 15th but looks like work is to be completed by Sept 30th.

Answer:

The RFP was reissued but we neglected to update the work completion date. The new work completion date should be November 30th, 2026.

Question 2:

The RFP references engineering to support the sign. Does this include engineering docs for the foundation or just the structural aspects. Our engineer typically calls for 3 1/2 inch posts for lateral stability but your docs call for a 2 7/8 inch pile.

Answer:

The proposed signage must be consistent in appearance and design with the existing signage already installed in the area. The engineered drawing provided with the RFP was an example of previously completed signage. The successful proponent must provide engineering documentation for the complete proposed sign installation, including the sign structure, supports, connections, and foundation. The proponent's engineer must determine the appropriate post and pile dimensions for the proposed installation and site conditions; the 2⁷/₈-inch pile shown in the example of the work that was completed in this area previously but is not a prescribed size.

Question 3:

Is the welding mandatory for uniformity on highway signs or is there flexibility. We typically use two 3 /4 inch galvanized bolts for signs.

Answer:

Alternative connection methods, including bolted connections, may be proposed, provided they are approved by the proponent's engineer and maintain an appearance consistent with the existing signage in the area. The proponent must include the proposed connection details in its engineering documentation. The example drawing does not, by itself, make welding mandatory.

A signed copy of each Addendum must also be included with the bidder submission. Failure to include this Addendum may be cause for rejection. If you have any questions, please contact Shelby Hum at shelbyhum@cumberlandcounty.ns.ca

ALL OTHER SPECIFICATIONS, TERMS AND CONDITIONS REMAIN UNCHANGED.

Acknowledgement by Bidder:

Company Name: _____

Print Name: _____

Signed: _____

Date: _____

End of Addendum #1