Tender Number: RFP-MCC-2003

Design /Build Services – Splash Pad, Playground, Park

Addendum #3

The following modifications reflect a change to the RFP document

4.1 Splash Pad Requirements

Please add the following information:

The main water inlet will come from the Chapel Street side of the park which has a 150 mm main. The pressure there is at least 60 psi. The sewer needs to flow out to Mechanic Street

Public Works will connect from the edge of the property

Power access is available from Chapel Street and Mechanic Street.

4.4 Other Park Element Requirements

Please add the following information:

p) The main park entrance shall be on the Mechanic St side

6. Supplemental Information Available

Please add the following information:

PID for property is: 25235946


Online map tool is here:
https://gis8.nsgc.gov.ns.ca/NSCRS/

Streetview from end of Chapel Street:
https://www.google.com/maps/@45.6454006,-64.0521323,3a,75y,205.8h,86.51t/data=!3m7!1e1!3m5!1s8TWgAtWSh8QCXob-eV_qrQ!2e0!6s%2F%2Fgeo1.ggpht.com%2Fcbk%3Fpanoid%3D8TWgAtWSh8QCXob-eV_qrQ%26output%3Dthumbnail%26cb_client%3Dmaps_sv.tactile.gps%26thumb%3D2%26w%3D203%26h%3D100%26yaw%3D147.84184%26pitch%3D0%26thumbfov%3D100!7i13312!8i6656

Streetview from Mechanic Street:
https://www.google.com/maps/place/45%C2%B038'42.0%22N+64%C2%B003'09.7%22W/@45.6447921,-64.0529115,3a,75y,69.69h,83.25t/data=!3m6!1e1!3m4!1sqZaQ7TSdFBTiSOj0k-lLEw!2e0!7i13312!8i6656!4m5!3m4!1s0x0:0x0!8m2!3d45.6449988!4d-64.0527012

All property boundaries shown are from provincial mapping only.

Orthophoto#1



76 Mechanic Street Photo #2



Looking West Photo #3



Looking South Photo #4



Looking East Photo #5



Looking North Photo #6



End of Addendum #3