

## ADDENDUM NO. 1

### To all Bidders of Tender T-MCC-2106:

The following changes to the specifications and drawings are to be incorporated in the Tender Documents and must be taken into account when preparing a submission.

#### 1 DRAWINGS

##### 1.1 Drawing C200

###### .1 Notes, Delete Note 3

'3. Laterals to be disconnected from existing main and re-connected to proposed watermain.'

###### and replace with

'3. Laterals to be disconnected at curb stop and new laterals installed between curb stop and main and re-connected to proposed watermain.'

##### 1.2 Drawing C400

###### .1 Detail 2, delete the following:

- 50mm ASPHALT Surface (TYPE 'C')
- 100mm ASPHALT BASE (TYPE 'B')

###### and replace with

- 40mm ASPHALT Surface (TYPE 'C')
- 50mm ASPHALT BASE (TYPE 'B')

###### .2 Detail 4, delete the following:

- 50mm ASPHALT Surface (TYPE 'C')
- 100mm ASPHALT BASE (TYPE 'B')

###### and replace with

- 40mm ASPHALT Surface (TYPE 'C')
- 50mm ASPHALT BASE (TYPE 'B')

End of Addendum No. 1